



Energy Consumption and Greenhouse Gas Emissions Reporting

for the 12 month period: January to December 2017

Ontario regulation 397/11 under the Green Energy Act 2009 requires hospitals to report on their energy consumption starting in 2013. Hospitals are also required to develop an Energy Conservation and Demand Management Plan by July 1, 2014.

The table below represents the 2017 Energy Consumption and Greenhouse Gas (GHG) emissions for Almonte General Hospital.

Agency Sub-sector: AcuteChronic

Facility Description				Energy Type, Amount Purchased & Consumed			Total (calculated in Webform)	
Operation Name	Operation Type	Total Floor Area	Average Hours per week	Electricity	Natural Gas	Fuel Oil 1&2	GHG Emissions (kg)	Energy Intensity
Almonte General Hospital	Facilities used for hospital purposes	64253 ft ²	168	1,508,692 kWh	186,603 m ³	1060 litres	381,793.28966	54.52339
Hospital Administration	Administrative offices and related facilities	4405 ft ²	65	96,796 kWh	11,972 m ³	68 litres	24,494.95426	51.02489